



DEVELOPMENT SERVICES
ENGINEERING DIVISION
156 S. BROADWAY, SUITE 150
TURLOCK, CA 95380

PHONE: (209) 668-5520
FAX: (209) 668-5563
TDD: (800) 735-2929
engineering@turlock.ca.us

Date: October 3, 2019

Addendum No.: 3

City Project: 19-33, "Dried Solids Storage Area"

Plan holders:

See the attached addendum no. 3 prepared by AECOM consisting of 4 pages.

If you have any questions, please call me at (209) 668-5417 or email at sfremming@turlock.ca.us.

Sincerely,

Stephen Fremming
Senior Civil Engineer

ADDENDUM NO. 3

City of Turlock
Contract Documents and Construction Specifications
Project No: 19-33
Dried Solids Laydown Area

All bidders are hereby notified of the following modification to the contract documents, construction specifications and construction plans. This modification is to become a part of said contract documents, construction specifications and construction plans.

This Addendum shall supersede all previously issued specifications and drawings wherein it contradicts same. All other conditions remain unchanged. The following changes, modifications, corrections, clarifications, and/or additions as set forth herein shall apply to the above documents and shall be made a part thereof and shall be subject to all of the requirements thereof as though originally specified and/or shown.



Item No.	Reference	Description of Change
1.	Proposal: Bidding Form	Replace the Bidding Form with attached.
2.	Special Provisions, Section 8: Bid Item Descriptions	<p>Replace Bid Item 6 – Site Grading Disposal with the following:</p> <p><i>This is a unit-price bid item per ton of deleterious and oversized materials excavated from the project limits, screened from otherwise suitable materials, and disposed off-site.</i></p> <p><i>To determine final quantities and contract price the Contractor shall provide a minimum of 5 weigh tickets from the public scale at Turlock Transfer 1100 S. Walnut Road Turlock, CA 95380 of both unloaded and loaded trucks per each truck type used.</i></p> <p><i>Turlock Transfer is available to provide weight tags for the purposes of establishing the theoretical weight of loaded trucks at a cost of \$6 per weight tag cost of which shall be included in the unit price. The weigh tickets shall be used for the purpose of establishing a theoretical weight per load per truck.</i></p> <p><i>Payment under this bid item shall be authorized based on the theoretical weight established for each truck type and the number of full loads leaving the site verified by the Project Inspector.</i></p>
3.	Special Provisions, Section 8: Bid Item Descriptions	<p>Renumber Bid Item 21 to 21A - Permanent Project Roads: Curb and Gutter</p> <p>Insert Bid Item 21B - Permanent Project Roads: Vertical Curb</p> <p><u><i>Bid Item 21B - Permanent Project Roads: Vertical Curb</i></u></p> <p><i>This is a unit-price bid item per linear foot for vertical curb installed at the locations in the drawings and in accordance with the specifications and include all costs for materials, labor, equipment, and incidentals for installation of vertical curb including excavation.</i></p>

Clarifications:

- Only deleterious and oversized materials excavated from the project limits screened from otherwise suitable materials are required to be disposed off-site. Excess suitable material shall be retained on site within designated stockpile location as directed by Owner.

BIDDING FORM

(Addendum 2)

PROJECT NO.: 19-33
 PROJECT NAME: DRIED SOLIDS LAYDOWN AREA
 BID OPENING DATE AND TIME: _____
 CONTRACTOR: _____

Bid Item No.	Quantity/ Units	Description	Unit Price	Total Amount
1.	Lump sum	Mobilization/Demobilization (not to exceed \$100,000)	--	
2.	Lump sum	Permits, Traffic Control, and SWPPP	--	
3.	Lump sum	Sheeting, Shoring, Bracing and Excavation Safety Measures	--	
Site Grading				
4.	6.0 AC	Clearing, Stripping and Grubbing		
5.	Lump sum	Earthwork	--	
6.	3,000 TON	Disposal		
Drainage				
7.	4 EA	60-Inch-Diameter Manhole		
8.	680 LF	18-Inch HDPE Profile Wall Pipe		
9.	620 LF	24-Inch HDPE Profile Wall Pipe		
10.	9 EA	Single Grate Concrete Catch Basin		
Laydown and Washdown Areas				
11.	24,500 SF	Reinforced Concrete Washdown Area		
12.	Lump sum	Reinforced Concrete Vector Dump Facility	--	
13.	14,000 SY	Soil-Cement Subgrade		
14.	950 CY	Reinforced Concrete Push Wall		
15.	11,000 SY	Asphalt-Concrete Paving		
16.	1,000 LF	Valley Gutter		
Permanent Project Roads				

Bid Item No.	Quantity/ Units	Description	Unit Price	Total Amount
17.	12,000 SY	Subgrade Preparation		
18.	1,840 CY	Class 2 Aggregate Base		
19.	4,960 SY	Asphalt-Concrete Paving		
20.	3 EA	Commercial Driveway Access		
21.A	2,060 LF	Curb and Gutter		
21.B	340 LF	Vertical Curb		
22.	2,950 LF	Header Board		
Recycled Water Distribution				
23.	1 EA	Connection to Existing 8" RW Main		
24.	950 LF	6" C-900 PVC Distribution Pipe		
25.	3 EA	Fire Hydrants		
26.	10 EA	Line Valves		
Site Electrical				
27.	1,300 LF	12kV Electrical Duct Bank 4x4" and 2x2" Conduit		
28.	5 EA	4'x4' Electrical Pull Box		
29.	750 LF	2x1" Street Lighting Conduit		
30.	7 EA	No. 5 Electrical Pull Box		
31.	4 EA	Street Lighting Base		

Bidder has examined and carefully studied the Bidding documents and other related data identified in the Bidding Documents and the following Addenda, receipt of which is hereby acknowledged.

No. _____	Date _____	ADDENDA
No. _____	Date _____	Signed _____
No. _____	Date _____	Signed _____
No. _____	Date _____	Signed _____

TOTAL BID WRITTEN IN FIGURES: _____

TOTAL BID WRITTEN IN WORDS: _____